


CERTIFICATE OF COMPLIANCE

Certificate Number 20121019-EX6679
Report Reference EX6679-20121019
Issue Date 2012-OCTOBER-19

This is to certify that representative samples of the product as specified on this certificate were tested according to the current ULC requirements.

A Full Service Company capable of providing complete service to Halon, FM 200 (HFC-227ea), and Novec 1230 systems and components including:

1. Charging, recharging and hydrostatic testing of Halon, FM 200 and Novec 1230 system containers.
2. Repair and maintenance of all system components.
3. Determination of quality of Halons 1211 and 1301, HFC-227ea and Novec 1230.
4. Reconditioning of recovered Halons 1211 and 1301, HFC-227ea and Novec 1230 to acceptable quality requirements.
5. Dismantling of systems.
6. Field inspections, including certification of the integrity of installed systems.



Martin Oughton, President & General Manager

UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving ULC Mark services are provided on behalf of Underwriters Laboratories of Canada Inc. (ULC) or any authorized licensee of ULC. For questions, please contact a local ULC Customer Service Representative at www.ul.com/contactus

